



GreenGuard Gold

Certification 2026

Contact Us!

1-800-255-FLEX (3539)

www.jplflex.com



Indoor Air Quality (IAQ) is important in HVAC systems. The US EPA states that people spend 90% of their time indoors and that indoor air pollutants are 2 to 5 times higher than outdoors. This is why JPL has taken the steps to ensure that all HVAC flexible ducts that the company manufactures meet the strict requirements set forth by GREENGUARD®.

GREENGUARD® is an independent 3rd party testing facility operated by UL that test for Volatile Organic Compounds (VOC) emissions in various products. GREENGUARD® requires routine monitoring and annual testing of JPL products to maintain certification. The testing performed by GREENGUARD® ensures that JPL meets the stringent requirements for improved IAQ.

JPL's flexible ductwork received the GREENGUARD® Gold Certification which is the highest classification for IAQ. The GREENGUARD® Gold standard includes health based criteria for additional chemicals and also requires lower total VOC emissions levels to ensure that products are acceptable for use in environments such as schools and healthcare facilities. In addition to limiting emissions of more than 360 VOCs and total chemical emissions, GREENGUARD Gold Certified products must comply with requirements of the State of California's Department of Public Health "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers, Version 1.1 (2010)" (also known as California Section 01350).

When designing or building HVAC systems, install a flexible duct that has received the highest marks for Indoor Air Quality. For additional information and certification requirements for GREENGUARD please visit: [GreenGuard Gold Overview](#)



Contact JP Lamborn

JP Lamborn Co.

1-800-255-FLEX (3539)

jplsales@jplflex.com

www.jplflex.com



JP Lamborn Company - Plants in California, Colorado, Florida & Tennessee

@JPLambornCo

@JPLambornCo

@JPLambornCo

@JPLambornCo

@JPLambornCo

CERTIFICATE OF COMPLIANCE



JP Lamborn Co.

JPL Flexible Duct

Restrictions:

5901-420

Certificate Number

17 Feb 2006 - 16 Oct 2026

Certificate Period

Certified

Status

UL 2818 - 2022 Gold Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

Wall finishes are determined compliant in accordance with California Department of Public Health (CDPH) Standard Method V1.2-2017 using a Classroom Environment with an air change of 0.82 hr⁻¹ and a loading of 94.60 m²; and Wall finishes are determined compliant in accordance with California Department of Public Health (CDPH) Standard Method V1.2-2017 using an Office Environment with an air change of 0.68 hr⁻¹ and a loading of 33.40 m².

Product tested in accordance with UL 2821 test method to show compliance to emission limits on UL 2818. Section 7.1 and 7.2.



UL investigated representative samples of the identified Product(s) to the identified Standard(s) or other requirements in accordance with the agreements and any applicable program service terms in place between UL and the Certificate Holder (collectively "Agreement"). The Certificate Holder is authorized to use the UL Mark for the identified Product(s) manufactured at the production site(s) covered by the UL Test Report, in accordance with the terms of the Agreement. This Certificate is valid for the identified dates unless there is non-compliance with the Agreement.

GREENGUARD Gold Certification Criteria for Building Products and Interior Finishes

Criteria	CAS Number	Maximum Allowable Predicted Concentration	Units
TVOC ^(A)	-	0.22	mg/m ³
Formaldehyde	50-00-0	9 (7.3 ppb)	µg/m ³
Total Aldehydes ^(B)	-	0.043	ppm
4-Phenylcyclohexene	4994-16-5	6.5	µg/m ³
Particle Matter less than 10 µm ^(C)	-	20	µg/m ³
1-Methyl-2-pyrrolidinone ^(D)	872-50-4	160	µg/m ³
Individual VOCs ^(E)	-	1/2 CREL or 1/100th TLV	-

- (A) Defined to be the total response of measured VOCs falling within the C₆ – C₁₆ range, with responses calibrated to a toluene surrogate. Maximum allowable predicted TVOC concentrations for GREENGUARD Gold (0.22 mg/m³) fall in the range of 0.5 mg/m³ or less, as specified in CDPH Standard Method v1.2.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Particle emission requirement only applicable to HVAC Duct Products with exposed surface area in air streams (a forced air test with specific test method) and for wood finishing (sanding) systems.
- (D) Based on the CA Prop 65 Maximum Allowable Dose Level for inhalation of 3,200 µg/day and an inhalation rate of 20 m³/day
- (E) Allowable levels for chemicals not listed are derived from the lower of 1/2 the California Office of Environmental Health Hazard Assessment (OEHHA) Chronic Reference Exposure Level (CREL) as required per the CDPH/EHLB/Standard Method v1.2 and BIFMA level credit 7.6.2 and 1/100th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).

